

12/27/2024

Dear Sir:

We would like to certify that the 2S Concrete Sand from the Mill Creek Pit # 489 does confirm to the NCDOT specifications and is approved to use in NCDOT projects. We sampled material from this location on 12/20/2024 and it conformed to both NCDOT and ASTM-33 specifications.

Sincerely,

A handwritten signature in black ink, appearing to read 'Karen Newport', written in a cursive style.

Karen Newport
CEO

Aggregate Test Summary Report

GS Materials, Inc. - Blue

Water Sand & Gravel - Mill

Product Creek Pit

Stock 1 Quarr FA489

Material S2S - Sand, 2S

Project No	Sample No	Sample Date	Quantity	2	1.5	1 3/4	1/2	3/8	#4	#8	#10	#16	#30	#40	#50	#80	#100	#200	200+	#40 @	#200 @	LL	PI	FM	Tech
	QC-52	12/20/2020	2000					100	99	95		82	54		24		5	1.1						2.4	20143 - Whitney Howard