

BLUE WATER SAND & GRAVEL, INC.

01/12/2026

Dear Sir:

We would like to certify that the 2S Concrete Sand from the Mill Creek Pit # 489 does confirm to the NCDOT specifications and is approved to use in NCDOT projects. We sampled material from this location on 12/23/2025 and it conformed to both NCDOT and ASTM-33 specifications.

Sincerely,



Karen Newport
CEO

Aggregate Test Summary Report

Producer: GS Materials, Inc. - Blue Water Sand & Gravel - Mill Creek Pit

Stockpile: 1

Quarry: FA489

Material: S2S - Sand, 2S

Proj No	Sample No	Sampled Date	Qty	2	1.5	1	3/4	1/2	3/8	#4	#8	#10	#16	#30	#40	#50	#80	#100	#200	200+	#40 @	#200 @	LL	PI	FM	Tech
QC-55	12/23/25	2000								100	99	95		80	40		18	4	1.7				2.5	20141 - Aubrey Burnell		