



01/12/2026

Dear Sir:

We would like to certify that the 2S Concrete Sand from the Hall Pit # FA122 does confirm to the NCDOT specifications and is approved to use in NCDOT projects. We sampled material from this location on 12/29/2025 and it conformed to both NCDOT and ASTM-33 specifications.

Sincerely,



Karen Newport
CEO

A handwritten signature in black ink, appearing to read 'Karen' above 'Newport'. Below the signature, the name 'Karen Newport' is printed in a black, sans-serif font. Underneath that, the title 'CEO' is also printed in a similar font.

Aggregate Test Summary Report

Producer: GS Materials, Inc. - Hall Pit- Lemon Springs Stockpile: 1 Quarry: FA122 Material: S2S - Sand 2S

Proj No	Sample No	Sampled Date	Qty	2	1.5	1	3/4	1/2	3/8	#4	#8	#10	#16	#30	#40	#50	#80	#100	#200	200+	#40 @	#200 @	LL	PI	FM	Tech
	OC-391	12/29/25	200							100	100	95	84	54	19	5	3							2.5	2041-Aubrey Burnell	